

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 54/2025

Dated : 10.07.2025

It is certified that an inspection team headed by **Mujeeb ull Hasan** (Executive Engineer) (Name of officers with designation) from P.H.E D Narmadapuram PHE D Inspected the **ST .Charles Convent School Bharlay ,Seoni Malwa District Narmadapuram M.P.** (Name & Address of the school)on **10.07.2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing No. **DWTLNDPM/F-04/7.8/F-27** Dated **10.07.2025** Of District Water Testing Laboratory P.H.E.D Narmadapuram M.P. (PHED LAB) Certified that the **ST .Charles Convent School Bharlay ,Seoni Malwa District Narmadapuram M.P.** District Narmadapuram M.P.(Name of school) has safe drinking water facilities for the Students and Members of staff of the institution .School is also maintains the hygienic sanitation Condition in the school building & the campus as per norms prescribed by the Central /State /U.T Govt.

This certificate is valid till : 10.07.2025 TO 09.07.2026

Signature with Seal :

Name

Mujeeb ull Hasan

Designation

Executive Engineer

Name & Address of the office/Department:Narmadapuram

To,

**ST .Charles Convent School Bharlay ,Seoni Malwa
District Narmadapuram M.P.**

.....
(Name&Address of the Institution)

Note:The certificate is to be issued by authorized officer /PHED Lab/Local Bodies

DWTLNDPM/F-04 /7.8/F-27



DISTRICT WATER TESTING LABORATORY

Public Health Engineering Department

Kothi Bazar ,Narmadapuram (M.P) 461001

Test Report

Status of Sample	Drinking Water	Unique Identification NO.	Report Date 10-07-2025
Sender's name	ST. Charles Convent School	Sender's letter no.	SCCS/25 – 26 /52
Sender's address	Bharlay Seoni Malwa District : Narmadapuram	Sender's letter date	08.07.2025
		Start Date of Analysis	08-07-2025
Quantity of sample	1000 ml	DWTL receipt No.	
Sample collected by lab(YES/NO)	No	End Date of Analysis	09.07.2025

Sample details:


S.No	Block	Gram panchyat	Village/Town	Habitation	Location
1	Seoni Malwa	Bharlay	Bharlay	Bharlay	ST. Charles water Tank

Physical & Chemical Test Report With Details of Parameters Their Test Methods ,Units and specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS 10500:2012&Reaffirmed in Sep.2018		Test Result				
						Sample Numbers				
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	1	2	3	4	5
1	2	3	4	5	6	7				
1*	Temperature	°C								
2	Colour	BIS :3025 Part 4	Hazen scale	5	15	2.0				
3	Odour	BIS :3025 Part 5	aggregable			A				
4	Taste	BIS :3025 Part 8	aggregable			A				
5	Iron as Fe	BIS :3025 Part 53	Mg/l	1.0	1.0	0.20				

6 *	Nitrate as No3	BIS :3025 Part 34	Mg/l	45	45	15.0				
7 *	Fluoride as F	BIS :3025 Part 60	Mg/l	1.0	1.5	0.10				
8	Chloride as Cl	BIS :3025 Part 32	Mg/l	250	1000	94.0				
9	Total Alkalinity as CaCo3	BIS :3025 Part 23	Mg/l	200	600	138				
1 0	Calcium as Ca++	BIS :3025 Part 40	Mg/l	75	200	82.2				
1 1	Magnesium as Mg	BIS :3025 Part 46	Mg/l	30	100	22.4				
1 2	Total Hardness as CaCo3	BIS :3025 Part 21	Mg/l	200	600	278				
1 3 *	Sulphate as SO4	BIS :3025 Part 24	Mg/l	200	400	38.2				
1 4	pH	BIS :3025 Part 2	pH scale	6.5 to 8.5	6.5 to 8.5	7.64				
1 5	Turbidity	BIS :3025 Part 10	NTU	1.0	5.0	2.0				
1 6	Conductivity	BIS :3025 Part 14	µmho/cm	-	-	510				
1 7	TDS	BIS :3025 Part 16	Mg/l	500	2000	282				
1 8 *	Fecal Coliform (TTC)		Per 100 ml	Nil	Nil	0.00				
1 9 *	Total Coloform		Per 100 ml	Nil	Nil	0.00				
2 0 *	Residual Cl2			0.2	1.0	nil				

1. This report should not be produced partly or full without approval of signatory authority for legal purpose.
2. It is recommended that acceptable limit is to be implemented .Values in acces of those mentioned under "acceptable" render the water not suitable ,but stil may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternative source" in coloum 6 ,above with the sources will have to be rejected .
3. The results refer only to tested Sample and parameter tested .
4. Sample will be stored for a period of 15 days from the date of issue of report(for tests from serial No 1,5,6,7,13,18,19,20.
5. This lab does not hold any responsibility for variation in results for samples kept on hold and want to clarification .
6. The tests marked with an *are not under the process of accreditation by NABL .


CHEMIST
WATER TESTING LABORATORY
P.H.E. Division
Narmadaouram (M.P.)
 District Water Testing Laboratory
 P.H.E.D Narmadapuram